

BCA BC 051/23/1 Vol 8

22 April 2010

Meyer Engineering and Construction  
Pte Ltd  
30 Kallang Pudding Road  
Valiant Industrial Building  
#04-04  
Singapore 349312  
Attn: Mr Varun Aswani

Building Plan & Management Division  
Building Plan Department  
Tel: 63258652  
Fax: 63254437

Dear Sir

**APPLICATION FOR PERMISSION TO INSTALL VACUUM LIFT WITH RATED LOAD OF 180KG FROM PNEUMATIC VACUUM ELEVATOR LCC**


I refer to your application mentioned above.

2 I am pleased to inform you that permission is hereby granted for the installation and operation of VACUUM LIFT with rated load of 180kg bearing the type examination certificate number: NL 04-400-1001-069-01 from the Liftinstituut.

3 The permission is granted on the understanding that:

- a) in the absence of a Singapore Standard on such equipment the manufacturer's design and installation method in compliance with Directive 98/37/EC and Swedish standard for vertical platform lifts (SS 2097-7) form the basis of the design and installation standard for this equipment in this country;
- b) this permission may be reviewed when a Singapore Standard on such equipment is available in the future or as and when deemed necessary by the Commissioner of Building Control; and
- c) the installation of such equipment shall be supervised by a professional engineer and on completion the professional engineer shall submit to the Commissioner of Building Control his certificate of supervision as required under the Building Control Regulations.

Yours faithfully

  
THOMAS GOH SIEW HUAT  
for COMMISSIONER OF BUILDING CONTROL